



TOWN OF WELLESLEY

**457 WORCESTER ST.
WELLESLEY, MA 02481
Telephone 781-235-1300**

FIRE DEPARTMENT

**OFFICE OF FIRE PREVENTION
Deputy Chief
Charles DiGiandomenico
Fax 781-237-3161**

April 26th, 2017

To: Michael Zehner Planning Director

From: Deputy Chief DiGiandomenico

Re: PSI-17-01 900 Worcester Street

The Wellesley Fire Department has reviewed the project for 900 Worcester Street Recreation/Sports Complex, with regard to hydrant placement and emergency vehicle access. The fire department is requesting two additional hydrants on site. One located at the North west corner of the building and one located at the south east corner of the building. A three point turn around on the south east corner of the property to accommodate a fire truck. A swept path analysis to be conducted for the site as stated in 527 CMR 1 Chapter 18 of the state fire code.

All applicants are required to follow the Fire Chiefs requirement of a third party reviewer as provided by 527 CMR 1. The applicant is responsible for the third party Fire Protection Engineer (FPE) as determined by the Fire Chief and must pay that vendor directly. The FPE represents the Fire Chief/Fire Department as our subject matter expert from the initial plan review to approval of final occupancy permit, and the fee schedule of our current FPE vendor should be attached.

The Fire Department reserves the right for final approval at the time of issuing a building permit with further review of the complete set of building documents.

Sincerely,
Deputy Chief DiGiandomenico
Fire Prevention Officer

